
CLK Monitor Controller Link Node Errors 62: _CLK004_CheckNode62 -004



■ Variable Tables

| input variables | | | | | |
|-----------------|---------------|-----------|---------|-------|------|
| Name | Variable name | Data type | Default | Range | Des |
| EN | EN | BOOL | | | 1 (C |
| | | | | | 0 (0 |

| Name | Variable name | Data type | Default | Range | Description |
|--------------|---------------|-----------|---------|-----------|--------------------------|
| EN | EN | BOOL | | | 1 (ON): FB started. |
| | | | | | 0 (OFF): FB not started. |
| Unit No. | UnitNo | INT | &0 | &0 to &15 | |
| Local node | NodeNo | INT | &1 | &1 to &62 | |
| address | | | | | |
| Monitor node | CheckNodeNo | INT | &1 | &1 to &62 | |
| address | | | | | |

Output Variables

| Name | Variable name | Data type | Range | Description |
|-------------------|---------------|-----------|-------|---|
| ENO | ENO | BOOL | | 1 (ON): FB processed normally. |
| (May be omitted.) | | | | 0 (OFF): FB not processed or ended in an error. |
| Node status | NodeStatus | BOOL | | Shows the status of the specified node. |
| | | | | 1 (ON): Node normal |
| | | | | 0 (OFF): Node error |

Version History

| Version | Date | Contents |
|---------|---------|---------------------|
| 1.00 | 2004.6. | Original production |

Note

This manual is a reference that explains the function block functions.

It does not explain the operational limitations of Units, components, or combinations of Units and components. Always read and understand the Operation Manuals for the system's Units and other components before using them.